

*****IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER*****

TRIGGERED SOURCE MONITORING AND REPORTING VIOLATION:
GROUND WATER RULE

TRI COUNTY POINT WATER SYSTEM 2 PWS TX1200027 failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the ground water system during **September 2021**. This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523.

Triggered source samples (raw water samples) are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active ground water well. Failure to collect all required triggered source samples is a violation of the monitoring requirements and we are required to notify you of this violation.

We are taking the following actions to address this issue:

In order to return to compliance, we have to collect a raw sample from our well G1200027B. This raw sample, when taken to the lab will be marked as "RAW" with 0 chlorine residual. In order to return to compliance this raw sample will be collected on 2/27/23.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e. people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact CSWR-Texas at 1-866-301-7725 or email at support@cswr texaswateruoc.com.

*****IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER*****

**FAILURE TO SUBMIT A DISINFECTANT LEVEL QUARTERLY OPERATING
REPORT (DLQOR)**

TRI COUNTY POINT WATER SYSTEM 2 PWS TX1200027 has violated the monitoring and reporting requirements set by the Texas Commission on Environmental Quality (TCEQ) in title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

Type of violation: DLQOR

This violation occurred in the monitoring period(s) of 2Q2022, 4Q2019

We are taking the following actions to address this issue:

We have turned in our DLQOR during the correct compliance period to TCEQ and returned to compliance as of 05/07/2020 and 12/19/2022. We will continue to file the DLQOR in the proper timeframe moving forward.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e. people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact CSWR-Texas at 1-866-301-7725 or email at support@cswrtexaswateruoc.com.