

**\*\*\*IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER\*\*\***

**Monitoring, Routine (DBP), Major/ Chlorine**

TIMBERLANE WATER SYSTEM PWS 2020054 has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Results of regular monitoring are an indicator of whether or not your drinking water is safe from microbial contamination.

Type of violation: **DLQOR**

This violation(s) occurred in the monitoring period(s) 1Q2022, 4Q2021, 2Q2021, 1Q2021.

We are taking the following actions to address this issue:

We have provided TCEQ with our current DLQOR during the correct compliance period and have returned to compliance as of 09/03/2022.

For more information, please contact:

CSWR- Texas at 1-866-301-7725 or at 1630 Des Peres Rd Suite 140 Des Peres, MO 63131

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by **TIMBERLANE WATER SYSTEM**

Public Water System Number: **TX2020054**

**\*\*\*IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER\*\*\***

**TIMBERLANE WATER SYSTEM PWS 2020054** has violated the monitoring and reporting requirements set by Texas Commission on Environmental Quality (TCEQ) in Chapter 30, Section 290, Subchapter F. Even though these were not emergencies, as our customers, you have the right to know what happened and what we are doing (or did) to correct these situations.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During: (52): 2020, we did not monitor or test for LCR and therefore cannot be sure of the quality of your drinking water during that time.*

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for [these contaminants], how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which the follow-up samples were [or will be] taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were or will be taken
<i>LCR tap sampling 2020</i>	<i>5 / triennially</i>	0	<i>JUNE 1, 2020 – SEPT 30, 2020</i>	<i>10/04/2021 rcd</i>

**What is being done?**

In order to return to compliance, we collected a complete set of sample tap samples and reported the results to TCEQ and are no longer in violation as of 10/04/2021. We will continue to pull the scheduled samples and send notifications as necessary.

For more information, please contact:

CSWR- Texas at 1-866-301-7725 or at 1630 Des Peres Rd Suite 140 Des Peres, MO 63131

*Please share this information with all other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you by **TIMBERLANE WATER SYSTEM**  
Public Water System Number: **TX2020054**

**\*\*\*IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER\*\*\***

**Reporting Requirement(s) Not Met for TIMBERLANE WATER SYSTEM**

**PWS 2020054**

We are required to report the results of monitoring of your drinking water for specific contaminants on a regular basis by **MAR 2022, AUG 2021, AUG 2020**. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During **MAR 2022, AUG 2021, AUG 2020**, we did not report the results of monitoring for total coliform.

Our system failed to notify the state drinking water program as required by **MAR 2022, AUG 2021, AUG 2020**. Although public health was not impacted, as our customers, you have a right to know what happened and what we did to correct the situation.

**What should I do?**

There is nothing you need to do at this time. You do not need to boil your water or take other actions.

**What is being done?**

We collected distribution samples on 04/28/2022, 09/30/2021, 09/24/2020 and were no longer in violation. We will continue to monitor and report as necessary.

For more information, please contact:

CSWR- Texas at 1-866-301-7725 or at 1630 Des Peres Rd Suite 140 Des Peres, MO 63131

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by **TIMBERLANE WATER SYSTEM**  
Public Water System Number: **TX2020054**