

**\*\*\*Important Information About Your Drinking Water\*\*\***  
**Triggered Source Monitoring and Reporting Violation**  
**Ground Water Rule**  
**Timberlane Water System TX2020054 Sabine, County**

**TIMBERLANE WATER SYSTEM** PWS 2020054 failed to collect the required number of triggered source bacteriological samples for fecal indicator monitoring of the ground water system during **SEPT 2020**.

This monitoring is required by the Texas Commission on Environmental Quality's "Drinking Water Standards" and the federal "Safe Drinking Water Act," Public Law 95-523.

Triggered source samples (raw water samples) are used to monitor water quality and indicate if the water is free of fecal indicator bacteria. Following a positive routine total coliform result in our distribution system, our water system is required to submit one triggered source sample for every active ground water well. Failure to collect all required triggered source samples is a violation of the monitoring requirements and we are required to notify you of this violation.

We are taking the following actions to address this issue:

In order for us to return to compliance we collected raw samples from each of our wells and turned in the results to TCEQ and returned to compliance as of 12/10/2020. We will continue to collect the required number of samples to ensure the quality of the drinking water.

*Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

**If you have any questions regarding this violation, you may contact:**  
**CSWR- Texas at 1-866-301-7725**